




LOUDOUN COUNTY, VIRGINIA
Department of Fire, Rescue and Emergency Management

803 Sycolin Road, Suite 104 Leesburg, VA 20175
Phone 703-777-0333 Fax 703-771-5359



Memorandum



To: Marchant Schneider, Project Manager
From: Maria Figueroa Taylor, Fire-Rescue Planner
Date: August 17, 2009
Subject: Loudoun Water – Water Storage Facility
SPEX 2009-0020 & CMPT 2009-0006

Thank you for the opportunity to review the above captioned application.

The Fire-Rescue GIS and Mapping coordinator offered the following information regarding estimated response times:

PIN	Project name	Ashburn VFRC Lansdowne Station 22 Travel Time
114-25-6156	Loudoun Water	3 minutes, 52 seconds

Travel times are determined using ESRI GIS network analyst along the county's street centerline with distance and speed limit being the criteria. Travel time is reported in minutes and seconds. For the approximate response time two minutes is added for turnout time.

Project name	Ashburn VFRC Lansdowne Station 22 Response Times
Loudoun Water	5 minutes, 52 seconds

The Fire and Rescue Staff is not opposed the special exception request. However, the Applicant must demonstrate adequate access and circulation of emergency vehicles throughout the site at the time more specific plans are available. If you have any questions or need additional information, please contact me at 703-777-0333.

c: Project file

Teamwork * Integrity * Professionalism * Service